



CEBU I ELECTRIC COOPERATIVE, INC.

Bito-on, Dumanjug, Cebu

Tel. Nos.: +63 999 924 5719 – Smart; +63 917 659 8066 Globe

<https://www.cebeco-1.com>

Unscheduled Power Interruptions

DATE	TIME OFF	TIME ON	DURATION (HH:MM)	AFFECTED AREAS/MUNICIPALITY	REASON/CAUSE/ACTION TAKEN	WEATHER CONDITION
08/08/2023	8:30 AM	9:43 AM	1:13	3 Phase Line from Brgy. Pasil Santander going to portion of Brgy. Lagunde Oslob	Tripping of recloser due to the fallen bamboo on the primary line/Bamboo was removed	Fair
08/08/2023	9:03 PM	9:52 PM	0:49	3 Phase line from Poblacion Samboan to portion of Brgy. Lagunde Oslob	Tripping of recloser due to the fallen twigg that is shorted on the primary line/Twigg was removed	Fair
08/09/2023	3:53 PM	4:25 PM	0:32	3 Phase Line from Brgy. Pasil Santander going to portion of Brgy. Lagunde Oslob	Tripping of recloser due to leaking insulator at Daanglungsod Oslob/Damaged insulator was replaced	Fair
08/10/2023	4:42 PM	5:24 PM	0:42	3 Phase Line from Brgy. Pasil Santander going to portion of Brgy. Lagunde Oslob	Tripping of recloser due to leaking insulator at Hagdan Oslob/Damaged insulator was replaced	Fair
08/11/2023	7:35 PM	8:50 PM	1:15	3 Phase line from Poblacion Samboan to portion of Brgy. Lagunde Oslob	Tripping of recloser due to the fallen tree branch on the primary line/Tree branch was removed	Fair
08/13/2023	9:18 AM	10:44 AM	1:26	3 Phase line from Tomonoy Molaboal to Badian, Madridejos, Alegria	Contractor Of Solar St. Light Erecting A Lamp Post at Malhiao, Badian hit the primary line that resulted the tripping of substation breaker/ Damaged conductor was repaired	Fair
08/13/2023	3:13 PM	5:26 PM	2:13	3 Phase Line from Brgy. Pasil Santander going to portion of Brgy. Lagunde Oslob	Tripping of recloser due to leaking insulator at Hagdan Oslob/Damaged insulator was replaced	Fair

Thank you for understanding.

CEBECO I MANAGEMENT